



BURNSVILLE FIRE DEPARTMENT

100 Civic Center Parkway
Burnsville, MN 55337
Phone: 952-895-4570
www.burnsville.org

BURNSVILLE FIRE MUSTER Food Vendor Requirements

The Burnsville Fire Department would like everyone attending the Fire Muster to have a safe and enjoyable experience. To assist with the safety of our community, the Burnsville Fire Department will be inspecting all food vendors prior to and during the event. The following are some of the items that will be inspected.

LP Tanks

All LP tanks must be out of the walkway and secured (with a chain or cable) to an object that cannot tip over.

Fire Extinguishers

All food vendors that will be preparing or keeping food warm with an external source of heat must have at least one 10 pound ABC Dry Chemical Fire Extinguisher located in close proximity to the trailer/booth. The fire extinguisher must be unobstructed and easily accessible.

All food vendors that will be utilizing grease to cook food and have a fire extinguishing hood system must also have a class K Fire Extinguisher in close proximity to the cooking area. The fire extinguisher must be unobstructed and easily accessible.

Electrical Cords

Extension cords must be rated for outdoor use and used properly.

Accumulated Material

The area around the trailer/booth must be kept free of combustibles (boxes, garbage, etc.)

If you have questions, feel free to contact the Burnsville Fire Marshal at 952-895-4579.

FIRE SAFETY TIP

When using a fire extinguisher, remember to

Pull the pin

Aim the nozzle at the base of the fire

Squeeze the handle

Sweep the nozzle at the base of the fire